BUILDING ENVELOPE DETAILS

CONNECTING THE LAYERS IN THE ROOF, WALLS, AND FLOOR TOGETHER.



NOTES

1. THE GENERAL NOTES AND TYPICAL DETAILS ARE APPLICABLE TO ALL PARTS OF THE PROJECT AND SHALL BE READ IN CONJUNCTION WITH THE DRAWINGS AND THE PROJECT SPECIFICATIONS.
2. USE ONLY THE LATEST ISSUES OF ANY GOVERNMENT CODES, STANDARDS OR REGULATIONS MENTIONED IN THE FOLLOWING NOTES, UNLESS OTHERWISE INDICATED.
3. DRAWINGS AND DETAILS ARE INTENDED TO SHOW THE END RESULT OF DESIGN. MODIFICATIONS TO THE DESIGN NECESSARY TO SUIT SITE DIMENSIONS OR CONDITIONS SHALL BE SUBMITTED TO CONSULTANT FOR APPROVAL BEFORE PROCEEDING.
4. VERIFY LOCATIONS AND DIMENSIONS OF ALL OPENINGS, PIPE SLEEVES, ETC. AS REQUIRED WITH THE MECHANICAL AND ELECTRICAL CONTRACTORS.
5. DO NOT CUT THROUGH, CORE-DRILL OR OTHERWISE ALTER ANY EXISTING OR NEW PART OF THE STRUCTURE WITHOUT PRIOR APPROVAL OF ENGINEER.
6. DO NOT SCALE THE DRAWINGS.

All dimensions in Metric

REV#	YYYY-MM-DD	SUBMISSION INFORMATION
1	2020-03-31	ISSUED FOR CLIENT REVIEW

DISCLAIMER:
THIS DRAWING IS PROTECTED BY COPYRIGHT LAW, AND SHOULD NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE, EXCEPT BY WRITTEN PERMISSION OF MORRISON HERSHFIELD. CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND REPORT ANY ERRORS AND/OR OMISSIONS TO MORRISON HERSHFIELD.

PROFESSIONAL SEALS

CONCEPT APPROACH DRAWINGS

(NOT FOR CONSTRUCTION)

MORRISON HERSHFIELD
Suite 200, 2932 Baseline Road
Ottawa, ON K2H 1B1
Tel: 613 739 2910

PROJECT
TECHNICAL GUIDE FOR NORTHERN HOUSING

DRAWING
TATL'AHKIME BUILDING
CROSS SECTION
NEW WORK

DESIGN	DATE	SCALE
MFM	2020-03-31	As Shown
DRAWN: MSE	PROJECT NO. 1901150.01	
CHECKED: DK	DRAWING NO. BE-01	VERSION 01
APPROVED		

\\mh.local\data\Proj\2019\1901150\1-Technical Guide Northern Housing P\09. CAD\05 Model\Building Science\1901150\1-TahltanTatl'ahKime - BE.dwg Last Saved: 2020-03-31 3:56 PM by MEgan Plotted 2020-03-31 3:59 PM by Meghan Egan

BUILDING ENVELOPE DETAILS

CONNECTING THE LAYERS IN THE ROOF, WALLS, AND FLOOR TOGETHER.



NOTES

1. THE GENERAL NOTES AND TYPICAL DETAILS ARE APPLICABLE TO ALL PARTS OF THE PROJECT AND SHALL BE READ IN CONJUNCTION WITH THE DRAWINGS AND THE PROJECT SPECIFICATIONS.
2. USE ONLY THE LATEST ISSUES OF ANY GOVERNMENT CODES, STANDARDS OR REGULATIONS MENTIONED IN THE FOLLOWING NOTES, UNLESS OTHERWISE INDICATED.
3. DRAWINGS AND DETAILS ARE INTENDED TO SHOW THE END RESULT OF DESIGN. MODIFICATIONS TO THE DESIGN NECESSARY TO SUIT SITE DIMENSIONS OR CONDITIONS SHALL BE SUBMITTED TO CONSULTANT FOR APPROVAL BEFORE PROCEEDING.
4. VERIFY LOCATIONS AND DIMENSIONS OF ALL OPENINGS, PIPE SLEEVES, ETC. AS REQUIRED WITH THE MECHANICAL AND ELECTRICAL CONTRACTORS.
5. DO NOT CUT THROUGH, CORE-DRILL OR OTHERWISE ALTER ANY EXISTING OR NEW PART OF THE STRUCTURE WITHOUT PRIOR APPROVAL OF ENGINEER.
6. DO NOT SCALE THE DRAWINGS.

All dimensions in Metric

REV#	YYYY-MM-DD	SUBMISSION INFORMATION
1	2020-03-31	ISSUED FOR CLIENT REVIEW

DISCLAIMER:
THIS DRAWING IS PROTECTED BY COPYRIGHT LAW, AND SHOULD NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE, EXCEPT BY WRITTEN PERMISSION OF MORRISON HERSHFIELD. CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND REPORT ANY ERRORS AND/OR OMISSIONS TO MORRISON HERSHFIELD.

PROFESSIONAL SEALS

CONCEPT APPROACH DRAWINGS

(NOT FOR CONSTRUCTION)

MORRISON HERSHFIELD
Suite 200, 2932 Baseline Road
Ottawa, ON K2H 1B1
Tel: 613 739 2910

PROJECT
TECHNICAL GUIDE FOR NORTHERN HOUSING

DRAWING
TATL'AHKIME BUILDING CROSS SECTION NEW WORK

DESIGN	DATE	SCALE
MFM	2020-03-31	As Shown
DRAWN: MSE	PROJECT NO. 1901150.01	
CHECKED: DK	DRAWING NO. BE-02	VERSION 01
APPROVED		

\\mh.local\data\Proj\2019\1901150\01-Technical Guide Northern Housing P\08- CAD\05 Model\Building Science\1901150\01-TahltanTat'ahKime - BE.dwg Last Saved: 2020-03-31 3:50 PM by MEgan Plotted 2020-03-31 3:09 PM by Meghan Egan

BUILDING ENVELOPE LAYERS LEGEND

	FIRST WEATHER SEAL
	SECOND WEATHER SEAL
	INSULATION
	INTERIOR HUMIDITY SEAL
	AIR SEAL
	THREE SEALS COMBINED (SECOND WEATHER SEAL, INTERIOR HUMIDITY SEAL, AND AIR SEAL)

FIRST WEATHER SEAL
LIMIT THE BUILDING ENVELOPE'S EXPOSURE TO WATER AND SNOW. COMMONLY INCLUDES EXTERIOR WALL CLADDINGS AND ROOF SYSTEMS. FLASHINGS AND TRIMS ASSIST IN SHEDDING WATER AWAY FROM THE SURFACES OF THE WALL AND OPENINGS.

SECOND WEATHER SEAL
RESIST THE BULK MOVEMENT OF WATER AND AIDE IN DRAINAGE. COMMONLY SHEATHING MEMBRANES, TAPES, AND SEALANTS.

INSULATION
RESIST THE FLOW OF HEAT AND AIDE IN REGULATING INTERIOR TEMPERATURES. COMMONLY INCLUDES EXTERIOR AND INTERIOR STUD CAVITY INSULATION, SUCH AS XPS, BATT, AND CELLULOSE INSULATIONS.

THE DISTRIBUTION OF THE INSULATION WITHIN THE ASSEMBLY DEPENDS ON THE TYPE OF EXTERIOR INSULATION. IF VAPOUR IMPERMEABLE INSULATIONS (E.G. XPS, EPX, ETC.) ARE USED THEN TWO-THIRDS OF THE ASSEMBLY R-VALUE IS TO INSTALLED ON THE EXTERIOR. WITH THE REMAINING ONE-THIRD IS TO BE INSTALLED WITHIN THE STUD CAVITY. IF A MAJORITY OF THE R-VALUE IS LOCATED WITHIN THE STUD CAVITY THEN A VAPOUR PERMEABLE INSULATION MUST BE USED.

TO LIMIT CONDENSATION BUILD-UP WITHIN THE BUILDING ENVELOPE ENSURE CONTINUITY OF THE INSULATION BY LIMITING INSULATION BREAKS AND FILL ENTIRE CAVITIES TO PREVENT CONVECTIVE LOOPS FROM FORMING.

INTERIOR HUMIDITY SEAL
RESIST THE MOVEMENT OF WATER VAPOUR. COMMONLY POLYETHYLENE SHEET, SHEATHING MEMBRANE, ETC.

AIR SEAL
RESIST THE MOVEMENT OF AIR BETWEEN THE INDOOR AND OUTDOOR. COMMONLY SHEATHING MEMBRANES, POLYETHYLENE SHEETS, ETC.

THREE SEALS COMBINED
COMBINED SECOND WEATHER, INTERIOR HUMIDITY, AND AIR SEAL. TO BE APPLIED ON THE WARM SIDE OF THE INSULATION.

APPLY PRIMER ON SUBSTRATE AND INSTALL MEMBRANE IN ACCORDANCE WITH MANUFACTURER'S INSTALLATION RECOMMENDATIONS. ENSURE MEMBRANE SHEETS ARE LAPPED POSITIVELY TO SHED WATER AND OVERLAPPED BY A MINIMUM OF 6" (150 mm).

NOTE: THE CONTINUITY OF BARRIERS IS FUNDAMENTAL IN PROVIDING A HIGHLY EFFECTIVE BUILDING ENVELOPE. TO LIMIT VAPOUR, MOISTURE, AND AIR INFILTRATION SEAL AROUND PENETRATIONS AND OPENINGS (WHERE POSSIBLE), PATCH OR REPAIR DAMAGED MATERIALS, OVERLAP SHEETS, AND PROVIDE REDUNDANCY AT TRANSITIONS.



1 BE-03 ROOF OVERHANG DETAIL
SCALE 1:5



2 BE-03 ROOF TO WALL TRANSITION
SCALE 1:5

NOTES

1. THE GENERAL NOTES AND TYPICAL DETAILS ARE APPLICABLE TO ALL PARTS OF THE PROJECT AND SHALL BE READ IN CONJUNCTION WITH THE DRAWINGS AND THE PROJECT SPECIFICATIONS.
2. USE ONLY THE LATEST ISSUES OF ANY GOVERNMENT CODES, STANDARDS OR REGULATIONS MENTIONED IN THE FOLLOWING NOTES, UNLESS OTHERWISE INDICATED.
3. DRAWINGS AND DETAILS ARE INTENDED TO SHOW THE END RESULT OF DESIGN. MODIFICATIONS TO THE DESIGN NECESSARY TO SUIT SITE DIMENSIONS OR CONDITIONS SHALL BE SUBMITTED TO CONSULTANT FOR APPROVAL BEFORE PROCEEDING.
4. VERIFY LOCATIONS AND DIMENSIONS OF ALL OPENINGS, PIPE SLEEVES, ETC. AS REQUIRED WITH THE MECHANICAL AND ELECTRICAL CONTRACTORS.
5. DO NOT CUT THROUGH, CORE-DRILL OR OTHERWISE ALTER ANY EXISTING OR NEW PART OF THE STRUCTURE WITHOUT PRIOR APPROVAL OF ENGINEER.
6. DO NOT SCALE THE DRAWINGS.

All dimensions in Metric

REV#	YYYY-MM-DD	SUBMISSION INFORMATION
1	2020-03-31	ISSUED FOR CLIENT REVIEW

DISCLAIMER:
THIS DRAWING IS PROTECTED BY COPYRIGHT LAW, AND SHOULD NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE, EXCEPT BY WRITTEN PERMISSION OF MORRISON HERSHFIELD. CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND REPORT ANY ERRORS AND/OR OMISSIONS TO MORRISON HERSHFIELD.

PROFESSIONAL SEALS

CONCEPT APPROACH DRAWINGS

(NOT FOR CONSTRUCTION)

MORRISON HERSHFIELD
Suite 200, 2932 Baseline Road
Ottawa, ON K2H 1B1
Tel: 613 739 2910

PROJECT
TECHNICAL GUIDE FOR NORTHERN HOUSING

DRAWING
TATL'AHKIME BUILDING ENVELOPE DETAILS NEW WORK

DESIGN	DATE	SCALE
MFM	2020-03-31	As Shown
DRAWN: MSE	PROJECT NO: 1901150.01	
CHECKED: DK	DRAWING NO: BE-03	VERSION: 01
APPROVED: APP		

\\mh.local\data\Proj\2019\191150 01-Technical Guide Northern Housing PKB. CAD\05 Model\Building Science\190115001-TahltanTatl'ahKime - BE.dwg Last Saved: 2020-03-31 3:50 PM by MEgan Plotted 2020-03-31 3:09 PM by Meghan Egan

BUILDING ENVELOPE LAYERS LEGEND

	FIRST WEATHER SEAL
	SECOND WEATHER SEAL
	INSULATION
	INTERIOR HUMIDITY SEAL
	AIR SEAL
	THREE SEALS COMBINED (SECOND WEATHER SEAL, INTERIOR HUMIDITY SEAL, AND AIR SEAL)

FIRST WEATHER SEAL
LIMIT THE BUILDING ENVELOPE'S EXPOSURE TO WATER AND SNOW. COMMONLY INCLUDES EXTERIOR WALL CLADDINGS AND ROOF SYSTEMS. FLASHINGS AND TRIMS ASSIST IN SHEDDING WATER AWAY FROM THE SURFACES OF THE WALL AND OPENINGS.

SECOND WEATHER SEAL
RESIST THE BULK MOVEMENT OF WATER AND AIDE IN DRAINAGE. COMMONLY SHEATHING MEMBRANES, TAPES, AND SEALANTS.

INSULATION
RESIST THE FLOW OF HEAT AND AIDE IN REGULATING INTERIOR TEMPERATURES. COMMONLY INCLUDES EXTERIOR AND INTERIOR STUD CAVITY INSULATION, SUCH AS XPS, BATT, AND CELLULOSE INSULATIONS.

THE DISTRIBUTION OF THE INSULATION WITHIN THE ASSEMBLY DEPENDS ON THE TYPE OF EXTERIOR INSULATION. IF VAPOUR IMPERMEABLE INSULATIONS (E.G. XPS, EPX, ETC.) ARE USED THEN TWO-THIRDS OF THE ASSEMBLY R-VALUE IS TO INSTALLED ON THE EXTERIOR. WITH THE REMAINING ONE-THIRD IS TO BE INSTALLED WITHIN THE STUD CAVITY. IF A MAJORITY OF THE R-VALUE IS LOCATED WITHIN THE STUD CAVITY THEN A VAPOUR PERMEABLE INSULATION MUST BE USED.

TO LIMIT CONDENSATION BUILD-UP WITHIN THE BUILDING ENVELOPE ENSURE CONTINUITY OF THE INSULATION BY LIMITING INSULATION BREAKS AND FILL ENTIRE CAVITIES TO PREVENT CONVECTIVE LOOPS FROM FORMING.

INTERIOR HUMIDITY SEAL
RESIST THE MOVEMENT OF WATER VAPOUR. COMMONLY POLYETHYLENE SHEET, SHEATHING MEMBRANE, ETC.

AIR SEAL
RESIST THE MOVEMENT OF AIR BETWEEN THE INDOOR AND OUTDOOR. COMMONLY SHEATHING MEMBRANES, POLYETHYLENE SHEETS, ETC.

THREE SEALS COMBINED
COMBINED SECOND WEATHER, INTERIOR HUMIDITY, AND AIR SEAL. TO BE APPLIED ON THE WARM SIDE OF THE INSULATION.

APPLY PRIMER ON SUBSTRATE AND INSTALL MEMBRANE IN ACCORDANCE WITH MANUFACTURER'S INSTALLATION RECOMMENDATIONS. ENSURE MEMBRANE SHEETS ARE LAPPED POSITIVELY TO SHED WATER AND OVERLAPPED BY A MINIMUM OF 6" (150 mm).

NOTE: THE CONTINUITY OF BARRIERS IS FUNDAMENTAL IN PROVIDING A HIGHLY EFFECTIVE BUILDING ENVELOPE. TO LIMIT VAPOUR, MOISTURE, AND AIR INFILTRATION SEAL AROUND PENETRATIONS AND OPENINGS (WHERE POSSIBLE), PATCH OR REPAIR DAMAGED MATERIALS, OVERLAP SHEETS, AND PROVIDE REDUNDANCY AT TRANSITIONS.



1 BE-04 WINDOW HEAD AND SILL DETAIL
SCALE 1:5



2 BE-04 FOUNDATION WALL TRANSITIONS
SCALE 1:5

NOTES

1. THE GENERAL NOTES AND TYPICAL DETAILS ARE APPLICABLE TO ALL PARTS OF THE PROJECT AND SHALL BE READ IN CONJUNCTION WITH THE DRAWINGS AND THE PROJECT SPECIFICATIONS.
2. USE ONLY THE LATEST ISSUES OF ANY GOVERNMENT CODES, STANDARDS OR REGULATIONS MENTIONED IN THE FOLLOWING NOTES, UNLESS OTHERWISE INDICATED.
3. DRAWINGS AND DETAILS ARE INTENDED TO SHOW THE END RESULT OF DESIGN. MODIFICATIONS TO THE DESIGN NECESSARY TO SUIT SITE DIMENSIONS OR CONDITIONS SHALL BE SUBMITTED TO CONSULTANT FOR APPROVAL BEFORE PROCEEDING.
4. VERIFY LOCATIONS AND DIMENSIONS OF ALL OPENINGS, PIPE SLEEVES, ETC. AS REQUIRED WITH THE MECHANICAL AND ELECTRICAL CONTRACTORS.
5. DO NOT CUT THROUGH, CORE-DRILL OR OTHERWISE ALTER ANY EXISTING OR NEW PART OF THE STRUCTURE WITHOUT PRIOR APPROVAL OF ENGINEER.
6. DO NOT SCALE THE DRAWINGS.

All dimensions in Metric

REV#	YYYY-MM-DD	SUBMISSION INFORMATION
1	2020-03-31	ISSUED FOR CLIENT REVIEW

DISCLAIMER:
THIS DRAWING IS PROTECTED BY COPYRIGHT LAW, AND SHOULD NOT BE REPRODUCED IN ANY MANNER, OR FOR ANY PURPOSE, EXCEPT BY WRITTEN PERMISSION OF MORRISON HERSHFIELD. CONTRACTOR SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND REPORT ANY ERRORS AND/OR OMISSIONS TO MORRISON HERSHFIELD.

PROFESSIONAL SEALS

CONCEPT APPROACH DRAWINGS

(NOT FOR CONSTRUCTION)

MORRISON HERSHFIELD
Suite 200, 2932 Baseline Road
Ottawa, ON K2H 1B1
Tel: 613 739 2910

PROJECT
TECHNICAL GUIDE FOR NORTHERN HOUSING

DRAWING
TATL'AHKIME BUILDING ENVELOPE DETAILS NEW WORK

DESIGN	DATE	SCALE
MFM	2020-03-31	As Shown
DRAWN: MSE	PROJECT NO: 1901150.01	
CHECKED: DK	DRAWING NO: BE-04	VERSION: 01
APPROVED: APP		

\\mh.local\data\Proj\2019\1901150\01-Technical Guide Northern Housing P08\ CAD\05 Model\Building Science\1901150\01-TahltanTatl'ahKime - BE.dwg Last Saved: 2020-03-31 3:50 PM by MEgan Plotted 2020-03-31 3:59 PM by Meghan Egan